

NOTES
■ DESIGNED PER CALCS. #33468.
■ CONCRETE MIX USED IN POURING THIS PRODUCT SHALL USE FLY ASH AS AN ADMIXTURE.
■ ALL PARTS TO BE STENCILED: MFG DATE / PRODUCT ID / WEIGHT.

BILL OF MATERIALS


ITEM	UNIT QTY	QTY	PART NUMBER	DESCRIPTION
1	85.062 ft^3	85.062 ft^3	100006028	CONCRETE 5500 PSI #17 SCC LADWP
2	1	8	100002880	ANCHOR DOGBONE P52 8T X 6-3/4" GALV
3	1	8	100003019	TERMINATOR DUCT WITH SEAL 6IN T6000
4	1	2	100005939	PULL IRON OFFSET WITH REBAR .875DIA 4.5H GALV LADWP
5	1	40	100015105	INSERT 1/2IN PLASTIC PENNSYLVANIA STICK-ON
6	1	1	100017686	REINFORCING MAT 100017686




PLAN VIEW




SECTION A-A



SECTION B-B





SECTION C-C



SECTION D-D

LIFTING NOTES
■ INSTALLATION: THIS CONCRETE PRODUCT IS DESIGNED TO BE LIFTED AT 5500 PSI WITH 4 LIFT CONNECTIONS EQUALLY LOADED TO 4 LIFTING POINTS AT A MINIMUM 60° SLING ANGLE, MEASURED FROM HORIZONTAL.
■ DEMOLDING: THIS CONCRETE PRODUCT IS DESIGNED TO BE LIFTED AT 2500 PSI WITH 4 LIFT CONNECTIONS EQUALLY LOADED TO 4 LIFTING POINTS AT A MINIMUM 60° SLING ANGLE, MEASURED FROM HORIZONTAL.
*All rigging shall be design by a qualified professional. Loading diagrams show illustrations of possible rigging setups to achieve the required sling angle and load leg equalization. Other valid rigging configurations are possible. A qualified professional must be consulted prior to lifting.

RIGGING DIAGRAMS*			
INSTALLATION	C	DEMOLDING	C
			

BURY DEPTH:	7.2' - 9.7' to Top		
WATER LEVEL:	3.0'	APPROX. WEIGHT:	12823.82 Lbs
DESIGN SPEC:	AASHTO LRFD,ACI 318,ASTM C857	LOADING SPEC:	AASHTO HL-93
REINFORCEMENT TYPE:	Rebar	LIFTING TYPE:	Dogbone

Infrastructure
JENSEN
WWW.JENSENINFRASTRUCTURE.COM

©2026 Jensen Infrastructure - All rights reserved.
All materials appearing as Jensen Infrastructure documents and the like are proprietary work product and are protected under U.S. copyright and other laws.
Unless in conjunction with business conducted with Jensen Infrastructure , any use of Jensen Infrastructure work product without express, written consent is prohibited, and recipient is prohibited from distributing any and all work product to non-approved third parties under penalty of civil action.
This product shall only be produced in a Jensen Infrastructure facility.

REVISION HISTORY

REV	DESCRIPTION	DATE	APPROVED
C-1-1	REVISED CONCRETE DESCRIPTION	8/14/2026	

DESCRIPTION:	Riser 96192x26 Terminators LADWP H-202 G3 CASTING DRAWING		REV: C-1-1
PART NUMBER:	100009757	DRAWN BY: J. Prado	SHEET: 1 OF 1
CREATED:	10/23/2020	MODIFIED: 8/14/2026	

100009757.idw