
NOTES
■ IN COMPLIANCE WITH UNIFORM PLUMBING CODE (UPC), INTERNATIONAL PLUMBING CODE (IPC), AND STRUCTURAL LOADING REQUIREMENTS OF ASTM INTERNATIONAL
■ JENSEN PRECAST'S PRODUCT IS LISTED BY IAPMO R&T TO STANDARD PS 80. MODEL CL-750
■ MINIMUM ONE (1) ACCESS OPENING PER COMPARTMENT REQUIRED (AS SHOWN).
■ MUST BE INSTALLED PER "JENSEN PRECAST UNDERGROUND WASTEWATER PRECAST CONCRETE TANK INSTALLATION PROCEDURE" WHICH CAN BE FOUND AT https://www.jensenprecast.com/Tank-Installation-Procedure-d2106.pdf. THIS PROCEDURE ADDRESSES REQUIRED EXCAVATION, SITE PREPARATION, INSTALLATION, VENTILATION, AND WATER/VACCUM TESTING


BILL OF MATERIALS

ITEM	QTY	PART NUMBER	DESCRIPTION	WEIGHT (LBS)
1	1	200029085	Tank JP 750 Gallon 6 Inch Assembly EE Double Baffle	10214
2	1	200048858	200030650 Plumbing - JP 750 4 Inch Clarifier 24"E, 24"E Double Baffle	2
3	JOB SPECIFIC	100005850	CI RINGCOVER 24DIA B-5105-02/B-5105-R2 ASTM A48 CL35B CP O-RING GASKET OSI JENSEN/INTERCEPT	196
4	JOB SPECIFIC	100001524	Grade Ring D2432x3	87
5	JOB SPECIFIC	100001525	Grade Ring D2432x6	180
6	JOB SPECIFIC	100001526	Grade Ring D2432x12	365
7	JOB SPECIFIC	100012046	Plug Cover D2428x6 Slab Top	300

200030650.idw



ISO LAYOUT



SECTION

REVISION HISTORY			
REV	DESCRIPTION	DATE	BY
A	DRAWING CREATED	10/8/2019	T.Larson
B	TOP SLAB LIFTING AND PLUMBING UPDATED	2/9/2021	T.Larson
C	ACCESSORIES UPDATED	7/6/2022	E.FINE

MODEL: CL-750


BURY DEPTH:	1.1' - 6.0' to Top		
WATER LEVEL:	Below Structure	WEIGHT:	12170.82 Lbs
DESIGN SPEC:	ASTM C890,ACI 318	LOADING SPEC:	A-16 (AASHTO HS20-44)
REINFORCEMENT TYPE:		LIFTING TYPE:	

JENSEN PRECAST EST. 1968


WWW.JENSENPRECAST.COM

©2018 Jensen Precast- All rights reserved.
All materials appearing as Jensen Precast documents and the like are proprietary work product and are protected under U.S. copyright and other laws.
Unless in conjunction with business conducted with Jensen Precast, any use of Jensen Precast work product without express, written consent is prohibited, and recipient is prohibited from distributing any and all work product to non-approved third parties under penalty of civil action.

DESCRIPTION:	Tank JP 750 Gallon 4 Inch Layout Clarifier 24"E, 24"E Double Baffle LAYOUT REVIEW		REV: C-4
PART NUMBER:	200030650	DRAWN BY:	E. Fine
CREATED:	1/31/2019	MODIFIED:	6/27/2023
			SHEET: 1 OF 2



PLAN VIEW



CROSS SECTION

BURY DEPTH:	1.1' - 6.0' to Top			DESCRIPTION: Tank JP 750 Gallon 4 Inch Layout Clarifier 24"E, 24"E Double Baffle LAYOUT DRAWING	REV: C-4
WATER LEVEL: Below Structure	WEIGHT: 12170.82 Lbs	JENSEN PRECAST EST. 1968 WWW.JENSENPRECAST.COM	©2018 Jensen Precast- All rights reserved. All materials appearing as Jensen Precast documents and the like are proprietary work product and are protected under U.S. copyright and other laws. Unless in conjunction with business conducted with Jensen Precast, any use of Jensen Precast work product without express, written consent is prohibited, and recipient is prohibited from distributing any and all work product to non-approved third parties under penalty of civil action.	PART NUMBER: 200030650	DRAWN BY: E. Fine	SHEET: 2 OF 2
DESIGN SPEC: ASTM C890,ACI 318	LOADING SPEC: A-16 (AASHTO HS20-44)			CREATED: 1/31/2019	MODIFIED: 6/27/2023
REINFORCEMENT TYPE:	LIFTING TYPE:				

200030650.idw