
NOTES


- ALL PARTS TO BE STENCILED: MFG DATE / JOB NUMBER / PRODUCT ID / WEIGHT.

BILL OF MATERIALS


ITEM	UNIT QTY	QTY	PART NUMBER	DESCRIPTION
1	3.647 ft^3	3.647 ft^3	100024079	CONCRETE #19 MOD SCC
2	1	8	100002867	ANCHOR DOGBONE P52 2T X 3-3/8" GALV
3	1	1	100008132	RFI PLASTIC TAG IDENCIA
4	1	1	300127203	REINFORCING MAT 300127203




PLAN VIEW




SECTION A-A



SECTION B-B



SECTION C-C



SECTION D-D

LIFTING NOTES

- DEMOLDING: THIS CONCRETE PRODUCT IS DESIGNED TO BE LIFTED AT 2,500PSI WITH 4 LIFT CONNECTIONS EQUALLY LOADED TO 4 LIFTING POINTS AT A MINIMUM 60° SLING ANGLE, MEASURED FROM HORIZONTAL.
- INSTALLATION: THIS CONCRETE PRODUCT IS DESIGNED TO BE LIFTED AT 5,500PSI WITH 4 LIFT CONNECTIONS EQUALLY LOADED TO 4 LIFTING POINTS AT A MINIMUM 60° SLING ANGLE, MEASURED FROM HORIZONTAL.

BURY DEPTH:	2' - 2' to Top		
WATER LEVEL:	3'	WEIGHT:	551.27 Lbs
DESIGN SPEC:	ASTM C857,ACI 318	LOADING SPEC:	A-16 (AASHTO HS20-44)
REINFORCEMENT TYPE:	Rebar	LIFTING TYPE:	Dogbone

JENSEN PRECAST EST. 1968

WWW.JENSENPRECAST.COM

©2019 Jensen Precast- All rights reserved.
All materials appearing as Jensen Precast documents and the like are proprietary work product and are protected under U.S. copyright and other laws.
Unless in conjunction with business conducted with Jensen Precast, any use of Jensen Precast work product without express, written consent is prohibited, and recipient is prohibited from distributing any and all work product to non-approved third parties under penalty of civil action.

REVISION HISTORY

REV	DESCRIPTION	DATE	APPROVED
B-1	INITIAL RELEASE	4/7/2021	

DESCRIPTION:	Pull Box 2436 X 4 Slab Bottom Sump CASTING LAYOUT		REV: B-1
PART NUMBER:	200047601	DRAWN BY: S. Rodarte	SHEET: 1 OF 1
CREATED:	1/3/2019	MODIFIED: 4/7/2021	

200047601.idw